

Clarification to Tender Notification CSO/04/ O & M Materials Dt.31.03.2008

A. Since 14.04.2008 is a holiday, last date of submission of Bid & Bid opening stands extended up to 18.04.2008 in place of 14.04.2008

B. Following clauses of above Tender published in our Web Site are rectified .

1. Page No. -30 of 85 – Group –A Sl. No. 1) 11 KV 200 Amp 3 Pole AB Switch-
Guaranteed Technical Particulars – Sl No. -26 :- **Note 1 & 2 are deleted.**
2. Page No. -52 of 85 – Group –E-LT XLPE Cable Unarmed Cable Clause No. -1-
Scope- Paragraph- 5 line -1 be read as follows :-
The **LT Cable** (in place of **Aerial Bunched**) shall conform x x x
3. Page No. -54 of 85 – Group –E- LT XLPE Cable Unarmed Cable Clause No. - 6)
Conductors :-
 - i) Line -1 will be read as follows :-
The (**Phase & Street light** now deleted) conductors shall be x x x
 - ii) Line -5 will be read as follows :-
XLPE (**AB** now deleted) Cables supplied shall satisfy x x x
4. Page No. - 48 of 85 – Group – D : Sl. No. – 1) LT Distribution Box Technical
Specifications , Para-5 of Clause -4 (Description of Materials) will be read as **Box
Electrolytic Aluminum** instead of **Box Electrolytic Cooper.**
5. Page-49 of 85 Group – D : Sl. No. – 1) **LT Distribution Box** Technical
Specifications ,Clause -4 (Description of Materials) :- A new points to be added after
(viii) :-
 - (ix) (ICS) Breaking capacity of MCCB shall be 25 KA minimum.
6. Page No- 61 of 85 Group-F – Sl. No. -1 **33/.433 KV ,100 KVA Station
Transformer** - Clause No. 6.2.1 of Technical Specification to be read as follows :-
Tap Changer - off circuit tap changer to be provided with tap position + 5% to -5%
and 2.5 % at each step. Provision shall be made for locking of Tap switch handle using a
Pad Lock.

7. Page No- 75 of 85 Group-F – Sl. No. -1 :- **33/433 KV ,100 KVA Station Transformer** , Sl No -15 of Table – B of Guaranteed & other Technical Particulars :-
Details of tapping provided on HV side – **Applicable** in stead of **Not Applicable**.
8. Any other clarification if required will be published in this page.